

Delegated Report

Development Planning

Address: 235 Regent Street, London, W1B 2EL,

Case No.:	15/05568/FULL	TP:	TP/1433 : PP-04288424
Date of Application:	19.06.2015	Date Valid:	09.07.2015
Date amended/ completed:	09.07.2015	8 Wk Date:	03.09.2015
Agent:	Stuart Hammond / DP9	On behalf of:	
Development Plan Context:	- London Plan July 2011 - Westminster's City Plan: Strategic Policies 2013 - Unitary Development Plan (UDP) January 2007		

LB: II **CA:** Mayfair


Proposal:

Installation of metal louvres on the north and west elevations of the property at first floor level to serve an internal plant room.

Consultations:

RESIDENTS' SOCIETY OF MAYFAIR AND ST. JAMES'S *no objection*
 ENVIRONMENTAL HEALTH *no objection*
Crossrail - no objection, subject to information
 ADJOINING OWNERS AND OCCUPIERS
 No Consulted:
 No Replied:

SITE AND PRESS NOTICE
 Yes



Relevant Planning History:

None relevant.

Considerations:

Permission is sought for the installation of louvres on the north and west elevations of the building at the very rear to serve an internal plant room. The alterations are considered acceptable in design terms and subject to the response from Environmental Health it is also considered acceptable in amenity terms. The proposal is therefore recommended for conditional approval.

Recommendation:

Grant conditional planning permission.

Case Officer or Matthew Giles **Date:** 6 July 2015

Item No.

Morning Meeting Officer:

Reason (if over 8/13 wk deadline):

HM
27.8.15

DRAFT DECISION LETTER

Address: 235 Regent Street, London, W1B 2EL,
Proposal: Installation of metal louvres on the north and west elevations of the property at first floor level to serve an internal plant room.
Plan Nos: Noise Report dated 29/04/2015, Drawings: A-C0412, A-C-411.
Case Officer: Ken Powell **Direct Tel. No.** 020 7641 2927

Recommended Condition(s) and Reason(s) or Reason(s) for Refusal:

- 1 The development hereby permitted shall be carried out in accordance with the drawings and other documents listed on this decision letter, and any drawings approved subsequently by the City Council as local planning authority pursuant to any conditions on this decision letter.

Reason:

For the avoidance of doubt and in the interests of proper planning.

- 2 You must carry out any building work which can be heard at the boundary of the site only:

- * between 08.00 and 18.00 Monday to Friday;
- * between 08.00 and 13.00 on Saturday; and
- * not at all on Sundays, bank holidays and public holidays.

Noisy work must not take place outside these hours. (C11AA)

Reason:

To protect the environment of neighbouring residents. This is as set out in S29 and S32 of Westminster's City Plan: Strategic Policies adopted November 2013 and ENV 6 of our Unitary Development Plan that we adopted in January 2007. (R11AC)

- 3 All new work to the outside of the building must match existing original work in terms of the choice of materials, method of construction and finished appearance. This applies unless differences are shown on the drawings we have approved or are required by conditions to this permission. (C26AA)

Reason:

To make sure that the appearance of the building is suitable and that it contributes to the character and appearance of this part of the Mayfair Conservation Area. This is as set out in S25 and S28 of Westminster's City Plan: Strategic Policies adopted November 2013 and DES 1 and DES 5 or DES 6 or both and paras 10.108 to 10.128 of our Unitary Development Plan that we adopted in January 2007. (R26BE)

- 4 (1) Where noise emitted from the proposed plant and machinery will not contain tones or will not be intermittent, the 'A' weighted sound pressure level from the plant and machinery (including non-emergency auxiliary plant and generators) hereby permitted, when operating at its noisiest, shall not at any time exceed a value of 10 dB below the minimum external background noise, at a point 1 metre outside any window of any residential and other noise sensitive property, unless and until a fixed maximum noise level is approved by the City Council. The background level should be expressed in terms of the lowest LA90, 15 mins during the proposed hours of operation. The plant-specific noise level should be expressed as LAeqTm, and shall be representative of the plant operating at its maximum.

(2) Where noise emitted from the proposed plant and machinery will contain tones or will be intermittent, the 'A' weighted sound pressure level from the plant and machinery (including non-emergency auxiliary plant and generators) hereby permitted, when operating at its noisiest, shall not at any time exceed a value of 15 dB below the minimum external background noise, at a point 1 metre outside any window of any residential and other noise sensitive property, unless and until a fixed maximum noise level is approved by the City Council. The background level should be expressed in terms of the lowest LA90, 15 mins during the proposed hours of operation. The plant-specific noise level should be expressed as LAeqTm, and shall be representative of the plant operating at its maximum.

(3) Following installation of the plant and equipment, you may apply in writing to the City Council for a fixed maximum noise level to be approved. This is to be done by submitting a further noise report confirming previous details and subsequent measurement data of the installed plant, including a proposed fixed noise level for approval by the City Council. Your submission of a noise report must include:

- (a) A schedule of all plant and equipment that formed part of this application;
- (b) Locations of the plant and machinery and associated: ducting; attenuation and damping equipment;
- (c) Manufacturer specifications of sound emissions in octave or third octave detail;
- (d) The location of most affected noise sensitive receptor location and the most affected window of it;
- (e) Distances between plant & equipment and receptor location/s and any mitigating features that may attenuate the sound level received at the most affected receptor location;
- (f) Measurements of existing LA90, 15 mins levels recorded one metre outside and in front of the window referred to in (d) above (or a suitable representative position), at times when background noise is at its lowest during hours when the plant and equipment will operate. This acoustic survey to be conducted in conformity to BS 7445 in respect of measurement methodology and procedures;
- (g) The lowest existing LA90, 15 mins measurement recorded under (f) above;
- (h) Measurement evidence and any calculations demonstrating that plant and equipment complies with the planning condition;
- (i) The proposed maximum noise level to be emitted by the plant and equipment.

Reason:

Because existing external ambient noise levels exceed WHO Guideline Levels, and as set out in ENV 6 (1), (6) and (8) and ENV 7 (A)(1) of our Unitary Development Plan that we adopted in January 2007, so that the noise environment of people in noise sensitive properties is protected, including the intrusiveness of tonal and impulsive sounds; and as set out in S32 of Westminster's City Plan: Strategic Policies adopted November 2013, by contributing to reducing excessive ambient noise levels. Part (3) is included so that applicants may ask subsequently for a fixed maximum noise level to be approved in case ambient noise levels reduce at any time after implementation of the planning permission.

- 5 No vibration shall be transmitted to adjoining or other premises and structures through the building structure and fabric of this development as to cause a vibration dose value of greater than 0.4m/s (1.75) 16 hour day-time nor 0.26 m/s (1.75) 8 hour night-time as defined by BS 6472 (2008) in any part of a residential and other noise sensitive property.

Reason:

As set out in ENV6 (2) and (6) of our Unitary Development Plan that we adopted in January 2007, to ensure that the development is designed to prevent structural transmission of noise or vibration.

Informative(s):

- 1 In dealing with this application the City Council has implemented the requirement in the National Planning Policy Framework to work with the applicant in a positive and proactive way. We have

made available detailed advice in the form of our statutory policies in Westminster's City Plan: Strategic Policies adopted November 2013, Unitary Development Plan, Supplementary Planning documents, planning briefs and other informal written guidance, as well as offering a full pre application advice service, in order to ensure that applicant has been given every opportunity to submit an application which is likely to be considered favourably. In addition, where appropriate, further guidance was offered to the applicant at the validation stage.

- 2 Conditions 4 and 5 control noise from the approved machinery. It is very important that you meet the conditions and we may take legal action if you do not. You should make sure that the machinery is properly maintained and serviced regularly. (182AA)

.....
The implications of the Crossrail proposals for the application have been considered and the proposed development needs to take account of the construction of Crossrail and of the following **INFORMATIVE:**

Crossrail is very likely to have monitoring equipment both on the inside of the building and on its external facades. The equipment is installed under the Crossrail Act 2008 and records ground movements (measured automatically or manually) and is essential for the control of ground settlement impact on buildings during Crossrail's works. Prior to commencement of works on the premises please contact the **Crossrail Helpdesk** helpdesk@crossrail.co.uk - Tel: 0345 602 3813) as soon as possible to obtain details of any monitoring equipment installed in order to ensure that your works do not interfere with Crossrail's monitoring equipment.

Amended
27.8.15